

## Electrical Signaling

Electrical protective signaling systems are configurations of components used to produce alarm signals indicative of fire, smoke, sprinkler waterflow or other emergency and to produce supervisory signals indicative of conditions needing attention with respect to protection equipment or watch service. System configurations are classified according to where and how the signals are received. The categories are commonly designated as local, municipal, remote station, proprietary, emergency voice/alarm communication, emergency communication, and central station. Auxiliary systems are either local or proprietary systems interconnected with a municipal system.

This category presents the major system component categories and the integrated system configurations. The selection of components to form a hybrid system should be made only by those skilled in system design. Also, the suitability of any system application should be judged on the basis of the hazard(s) being protected.

## Alarm Signal Initiating Devices

Alarm signals are initiated either automatically or manually. Automatic detectors respond to changes in characteristic phenomena associated with fire or other emergency conditions.

## Fire Detection, Heat-Actuated

*Heat sensitive devices may be either "spot" or "line" type and operate at a fixed temperature or on a rapid increase in temperature (rate-of-rise). Some detectors combine the fixed and rate sensitive principles.*

*The spacing guides listed are indicative of each detector's relative sensitivity and, in each case, the spacing guide is the maximum recommended separation between detectors for smooth-ceiling installations. For a given temperature rating, a fixed-temperature detector which has a 30 ft (9 m) listing and one which has a 15 ft (5 m) listing will both respond at approximately the same time to a geometrically growing fire if each is installed at its listed spacing. FM Approved rate-of-rise detectors all have 30 ft (9 m) listed spacings, the maximum separation recommended by FM Approvals.*

*Installation of heat detectors at less than maximum spacing is necessary: to achieve earlier response; to compensate for ceiling obstructions such as beams and joists; and to compensate for ceiling heights greater than 15 ft (5 m). Proper location and use of heat detectors involves consideration of ceiling construction, the location of partitions, the maximum normal room temperature, heat produced by the occupancy, and whether detector function is to warn occupants or to automatically actuate protection equipment. Refer to Standard 72-1993 of the National Fire Protection Association and design specifications published by jurisdictional authorities, as appropriate.*

## Universal Low Resistance Series PLR, Types PLR, PLR-R, PLR-X and PLR-CR

Universal Low Resistance Series PLR, Types PLR, PLR-R, PLR-X and PLR-CR fixed temperature, heat-sensitive cable for area heat detection. Rated operating temperatures are: extra-low, 140°F (60°C) (Type PLR-X only); regular, 155°F (68°C); intermediate, 190°F (88°C), 220°F (105°C); high, 280°F (138°C). Type PLR and PLR-CR also has an extra high, 356°F (180°C) which is intended for proximity detection only. Rated for 30 V ac, 42 V dc. Spacing guide for "extra low", "regular", and 190°F (88°C) "intermediate" cable is 30 x 30 ft (9.1 x 9.1 m). 220°F (105°C) "intermediate" and "high" cables are rated 25 x 25 ft (7.6 x 7.6 m). "Extra high" cables are not intended for area coverage. PIM-530(LT) Interface Module operates on 12 or 24 V dc and provides relay and 4-20 mA outputs for connection to a compatible Approved control. PIM-530 operating temperature range is -20°F (-29°C){-40°F (-40°C) for LT version} to 120°F (49°C). PIM-530-EI, PIM -530-(LT)EI Interface Module is associated apparatus with intrinsically safe connections to Class I, II and III, Division 1, Groups A, B,C, D, E, F and G; [AEx ia Ga] IIC hazardous (classified) locations. Series PLR, Types PLR, PLR-R, PLR-X and PLR-CR fixed temperature, heat-sensitive cable heat detection and ZB-HD-5-QC Zone Boxes are intrinsically safe for use in Class I, II and III, Division 1, Groups A, B,C, D, E, F and G; Class I, Zone 0, AEx ia IIC T6 Ga -29°C ≤ Ta ≤ +49°C hazardous (classified) locations when connected via the PIM-530-EI or PIM -530-(LT)EI in accordance with Control Drawing IL1626.

<b>Company Name:</b>	The Protectowire Co., Inc
<b>Company Address:</b>	60 Washington St., Pembroke, Massachusetts 02359, USA
<b>Company Website:</b>	<a href="http://protectowire.com">http://protectowire.com</a>
<b>New/Updated Product Listing:</b>	No
<b>Listing Country:</b>	United States of America
<b>Certificate Number:</b>	
<b>Certification Type:</b>	FM Approved